



STQC Certification Services

Government of India
Ministry of Electronics and Information Technology
Electronics Niketan, 6 CGO Complex, New Delhi 110 003

Certificate of Registration

Registration Number S-Mark/NR/2014/014


This is to Certify That

**M/s Capital Power System Ltd.,
B-40, Sector-4,
District Gautam Budh Nagar,
Noida- 201301
Uttar Pradesh, India**

fulfills the requirements of

SAFETY CERTIFICATION ('S' MARK) SCHEME

The scope of this certificate of Approval covers :

Product	: Electronic Energy Meter
Model	: CS 12 , Rating: 1P 2W AC Static ,240V, 50Hz , (5-30)A, Class 1.0, IP51, 3200Imp/kWh CS 12S , Rating: 1P 2W AC Static Smart, 240V, 50Hz , (10-60)A, Class 1.0, IP51, 3200Imp/kWh CS 34, Rating: AC 3Ph 4 Wire, 10-60A, 3x240V, 50Hz, Class 1.0, 1600 Imp/kWh
Trademark	: 
Standard	: IEC 62052-31 Edition 1.0 2015
Manufactured at	: Capital Power System Ltd., B-40, Sector-4, District Gautam Budh Nagar, Noida- 201301, Uttar Pradesh, India

This certificate is valid up to : **05.07.2026**

Previous Certificate Details : **Certificate no 385 valid till 06.07.2023**

06.07.2023

Date

(A.K. Sharma, CEO)

(for STQC Directorate)

*"Clarifications (if any) regarding the scope of this certificate may be obtained from STQC Certification Services."
The validity of this certificate is subject to continued compliance verification in surveillance audits.*

